

EXHIBIT F-2

Attachment 2

Det
Chico

7/13/2021

Tech Info			Dispatch Info					FO Timestamp Info				Elapsed Times							Order Info												
Area	HQ	Tech	Order State	Order Dispatch Count	Dispatch User ID	Last Dispatch Timestamp	Returned to Pending	Date Taken Timestamp	Enroute Time	Onsite Time	Completed Time	Total Time Billed To Order	En Route Minutes	Expected HQ Drive Time	Variance	On Site Minutes	Total Expected CC Time	Variance	Order Number	Priority	Appointment Window	Address	Job Code 1	CC1	CC2	CC3	CC4	Office Remarks	Dispatcher Remarks	Tech Remarks	
Chico			Completed	6		07/13 07 02		07/01 12 48	08 21	08 43	09 12	50.8	21.8	10	11.8	29.0	29.0	0.0	0723599973	2	AD			2124	2126	2052		EMT.. INSTALL 200A 120/240 MTR CTC REP NOT #1196600225		Insta l serv, set mtr, chk vo t ok. Left main off	
			Completed	6		07/13 07 02		07/01 13 04	09 12	09 12	09 28	15.6	0.0	10	-10.0	15.5	29.0	-13.5	0727711720	2	AD			2124	2126	2052		EMT.. INSTALL 200A 120/240 MTR CTC REP NOT #1196600225		Insta l ser, chk volt and set mtr. Left main off	
			Completed	6		07/13 07 02		07/01 12 35	09 28	09 28	09 46	18.4	0.0	10	-10.0	18.4	29.0	-10.6	0729799710	2	AD			2124	2126	2052		EMT.. INSTALL 200A 120/240 MTR CTC REP NOT #196600225		Insta l ser, chk volt ok, set mtr. Left main off	
			Completed	6		07/13 07 02		07/01 13 02	09 47	09 47	10 01	14.2	0.0	10	-10.0	14.2	29.0	-14.8	0720969708	2	AD			2124	2126	2052		EMT.. INSTALL 200A 120/240 MTR CTC REP NOT #196600225		Insta l serv, chk volt and set mtr. Left main off	
			Completed	2		07/13 10 28		07/13 10 26	10 53	11 21	11 43	49.9	27.6	10	17.6	22.3	20.0	2.3	6713119073	1	AD			2220	2220			GIVE TO TMAN		Insp panel repairs ok, reconn and chk volt ok. Mtr tech to change out bad mtr	
			Completed	4		07/13 10 47		07/13 09 36	11 43	12 29	23 02	678.6	45.7	10	35.7	632.9	25.2	607.7	0009119619	1	AD	UNKNOWN PREMISES DO NOT CHANGE STORRIE		1240	1190			CHECK FUSE 805 - BUCKS CREEK 1101 - PER D O	PARADISE TAG PER TMAN	Found tree on line with 2 fuses blown and 1 still energized, open remaining. Ca led for 911	
			Reassigned	1		07/13 13 04		07/13 13 04			14 59								T005340710	0	AD			9060				AXS-LOCKED GATE 3 DOGS LAB MIXER- WAS WORKING IN THE CUSTOMERS YARD AND HIT AN ELEC TRIC LINE THEY WERE ABLE RESET THE BREAKER FOR POWER			
Chico			Completed	5		07/13 06 54		07/08 14 56	07 07	10 13	10 15	187.7	185.9	10	175.9	1.9	20.0	-18.1	0667878152	2	AD			2094	2094			(2) T-MAN TO INSTALL 140' NEW 4/0 TPX SVC & SET 200A 120/240 1P B10S MTR - FLD CNT @ REP PM35249582 N#120875189	TAG ON 2 TMAN A	set meter	
			Completed	1		07/06 19 04		07/06 19 04	10 19	10 55	11 32	72.8	35.7	10	25.7	37.1	0.0	37.1	W106700003	2	UD			W110	W110						

Det
Chic 7/13/2021

Tech Info			Dispatch Info					FO Timestamp Info				Elapsed Times							Order Info												
Area	HQ	Tech	Order State	Order Dispatch Count	Dispatch User ID	Last Dispatch Timestamp	Returned to Pending	Date Taken Timestamp	Enroute Time	Onsite Time	Completed Time	Total Time Billed To Order	En Route Minutes	Expected HQ Drive Time	Variance	On Site Minutes	Total Expected CC Time	Variance	Order Number	Priority	Appointment Window	Address	Job Code 1	CC1	CC2	CC3	CC4	Office Remarks	Dispatcher Remarks	Tech Remarks	
			Completed	1		07/13 07:48		07/13 07:48	11:58	11:58	13:43	105.6	0.0	10	-10.0	105.5	5.6	99.9	T005340260	0	AD			9190	0930				AXS-OK NON CUSTOMER STATES BRANCHES ENTANGLED IN LINES CAUSING WIRE TO SAG . MOVE IN ANOTHER DIRECTION, FEELS HAZARDOUS, NEAR CH ICO HIGH SCHOOL		Phone
			Completed	1		07/13 14:59		07/13 14:59	14:59	15:52	15:53	53.6	52.8	10	42.8	0.8	5.6	-4.8	T005340856	0	AD			9060	0930				AXS-LOCKED GATE YSTR 3 DOGS LAB MIXES- WAS WORKING IN THE CUSTOMERS YARD AND HIT AN ELEC TRIC LINE THEY WERE ABLE RESET THE BREAKER FOR POWER		customer side of meter
			Completed	4		07/13 14:58		07/13 12:27	15:57	16:40	16:41	43.6	42.8	10	32.8	0.8	5.6	-4.8	0689701891	0	AD			1160	0930				No Access or Safety Issues; POLE TO CALLERS HOUSE; WIRE HANGING 2 FEET ABOVE A TRUCK ON THE STREET; CONTACT NAME		phone
			Completed	2		07/13 16:35		07/13 16:28	16:42	16:42	16:43	0.9	0.0	10	-10.0	0.9	5.6	-4.7	0686573094	0	AD			1160	0930				Access/Safety Dog(s); AXS UNKNOWN, WIRE LOW RUNNING ACCROSS THE STREET STATES THAT IF A TRUCK PASSES BY THEY WILL TAKE TH WIRE WITH THEM WIRE CALLED IN TWO HOURS AGO FROM NEIGHBORHS ADDRESS AND NO ON HAS ARRIVED YET		phone

Det
Chic 7/13/2021

Tech Info			Dispatch Info					FO Timestamp Info				Elapsed Times							Order Info												
Area	HQ	Tech	Order State	Order Dispatch Count	Dispatch User ID	Last Dispatch Timestamp	Returned to Pending	Date Taken Timestamp	Enroute Time	Onsite Time	Completed Time	Total Time Billed To Order	En Route Minutes	Expected HQ Drive Time	Variance	On Site Minutes	Total Expected CC Time	Variance	Order Number	Priority	Appointment Window	Address	Job Code 1	CC1	CC2	CC3	CC4	Office Remarks	Dispatcher Remarks	Tech Remarks	
			Completed	1		07/13 15:20		07/13 15:20	16:44	18:23	18:24	100.5	99.6	10	89.6	0.9	5.6	-4.7	T005340873	1	AD							AXS-DOGS ON PREMISE XSTR-COHESSET PWR-I CUSTOMER IS OUT OF POWER, PREVIOUS TR REPORT ON FILE HOWEVER ISSUE NOT RESOLVED. CUSTOMER STILL HAS NO POWER. CUSTOMER STATED DAMAGED ELECTRICAL METER BOX WAS DAMAGED BY AN UMBRELLA.		meter problem	
			Completed	1		07/13 15:50		07/13 15:50	18:49	19:15	19:16	26.7	26.0	10	16.0	0.7	5.6	-4.9	T005340908	1	AD							AXS-OK XSTR-NORD PWR-Y NO ELECTRIC SERVICE, WENT OUT APPROX. 10PM YESTERDAY, PWR ON PER SSNCKD MAIN OUTSIDE,AND GFI IN BATHROOM		breaker	
			Cancelled	2		07/13 06:22		07/08 14:56			06:53								X316144369	2	AD							(2) T-MAN TO INSTALL 140' NEW 4/0 TPX SVC & SET 200A 120/240 1P B10S MTR - FLD GNT			
			Reassigned	1		07/13 16:21		07/13 16:21			16:27								T005340928	1	AD							AXS-AXS OK XSTR-QUARTZ ST PWR-I WIRE DOWN ACCROSS THE ROAD IF A TRUCK DRIVE STHROUGH THEY RE TAKING THE LINE WITH THEM. CALL			